



Date of Issue: 4/7/2022 Report Number: 22-001280

Revision Number:1

Date Order Received: 03/30/2022

For the Account of:

Carnegie Fabrics LLC 110 North Centre Avenue Rockville Centre, NY 11570

Client's Identification:	Narcis					
		RTIFICATE OF	_			
TEST PERFORMED: NFPA 70	01 Standard Methods of	Fire Test for Flame	e Propagation of Te	xtiles and Films 2	019 – Test #1	
TEST RESULTS						
Specime	en Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)	
1	11.0	8.2	25	0.0	0.0	
2	11.1	8.1	27	0.0	0.0	
3	11.0	8.7	21	0.0	0.0	
4	11.0	8.7	21	0.0	0.0	
5	10.9	8.2	25	0.0	0.0	
6	10.9	8.2	25	0.0	0.0	
7	11.0	8.3	25	0.0	0.0	
8	11.0	8.1	26	0.0	0.0	
9	10.9	8.4	23	0.0	0.0	
10	10.9	8.3	24	0.0	0.0	
Average	11.0	8.3	24	0.0	0.0	
Approximate weight (oz./sq. yd): 5.4 Standard Deviation: 2.0 Average + 3 SD: 30.0					0	
Product Configuration:	⊠ Single Layer	☐ Multi Layer				
Conditioning:	☑ Oven at 220°F for minimum 30 minutes			☐ 70 ±2°F & 65 ±2%RH for minimum 24 hours		
Intended End-use (if known & other than drapery): Drapery						
Afterflame is required to be recorded; however, it is not factored into the Acceptance Criteria 1. Where fragments or residues of specimens that fall to the floor of the test chamber continue to burn for more than an average of 2 seconds per specimen for the sample of 10 specimens, the material shall be recorded as failing. (Flaming Drip) 2. Where the average weight loss of the 10 specimens in a sample is greater than 40 percent, the material shall be recorded as failing. 3. Individual specimens will be listed as a failure if it exceeds mean + 3 SD 4. Where the specimens do not demonstrate performance in accordance with either of the conditions indicated above, the material shall be recorded as passing this test and shall be designated as flame resistant.						
CONCLUSION Based on the above Results and Acceptance Criteria, the item tested: □ Complies □ Does Not Comply						
CERTIFICATION I certify that the specified by the standard stated and stated		ed after testing speci	men in accordance w	ith the procedures a	and equipment	

553 76th Street, Byron Center, MI 49315

Authorized Signature

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 1

Date Order Completed: 04/06/2022